DEPARTMENT OF TRANSPORTATION

DIVISION OF ENGINEERING SERVICES

Office of Structural Materials

Quality Assurance and Source Inspection

Bay Area Branch 690 Walnut Ave.St. 150 Vallejo, CA 94592-1133 (707) 649-5453 (707) 649-5493



Contract #: 04-0120F4

Cty: <u>SF/ALA</u> Rte: <u>80</u> PM: <u>13.2/13.9</u>

File #: 69.28

WELDING INSPECTION REPORT

Resident Engineer: Siegenthaler, Peter **Report No:** WIR-019349 **Address:** 333 Burma Road **Date Inspected:** 09-Jan-2011

City: Oakland, CA 94607

Project Name:SAS SuperstructureOSM Arrival Time:700Prime Contractor:American Bridge/Fluor Enterprises, a JVOSM Departure Time:1900

Contractor: Zhenhua Port Machinery Company, Ltd (ZPMC), Changxing Island Location: Shanghai, China

CWI Name: CWI Present: Yes Xu Xian Ping No **Inspected CWI report:** Yes N/A **Rod Oven in Use:** Yes No No N/A N/A **Electrode to specification:** Yes No Weld Procedures Followed: Yes No N/A N/A **Qualified Welders:** Yes No **Verified Joint Fit-up:** Yes No N/A N/A N/A **Approved Drawings:** Yes No **Approved WPS:** Yes No Yes No N/A **Delayed / Cancelled:**

Bridge No: 34-0006 Component: Orthotropic Box Girder (OBG)

Summary of Items Observed:

On this date Caltrans Office of Structural Material (OSM) Quality Assurance (QA) Inspector, D.Sukanthan was present during the time noted above for observations relative to the work being performed.

This QA Inspector randomly observed the following work in progress:

OBG # CROSSBEAM CB17

This QA observed that no significant work was being performed on this crossbeam during the time QA was present.

OBG # CROSSBEAM CB18

This QA observed that no significant work was being performed on this crossbeam during the time QA was present.

OBG # CROSSBEAM CB19

This QA observed that no significant work was being performed on this crossbeam during the time QA was present.

OBG # BAY 8

WELDING INSPECTION REPORT

(Continued Page 2 of 2)

This QA observed ZPMC qualified welding personnel identified as 500405 perform Flux Cored Arc Welding (FCAW) Process on weld joint BK004A6-064-002. ZPMC Quality Control Personnel (QC) identified as Mr. Feng ya jun was present to monitor the welding process. The welding parameters as measured using QC's calibrated instruments appeared to be in general compliance with WPS-B-T-2232-ESAB.

This QA observed ZPMC qualified welding personnel identified as 069894 perform Shielded Metal Arc Welding (SMAW) Process repair welding on weld joint BK004A1-062-043. ZPMC Quality Control Personnel (QC) identified as Mr. Feng ya jun was present to monitor the welding process. The welding parameters as measured using QC's calibrated instruments appeared to be in general compliance with WPS-345-SMAW-2G (2F)-Repair and Critical Weld Repair B-CWR2481 Rev no 1.

OBG # BAY 10

This QA observed ZPMC qualified welding personnel identified as 040533 perform Shielded Metal Arc Welding (SMAW) Process on weld joint BK004A6-033-002,007. ZPMC Quality Control Personnel (QC) identified as Mr. Yu zhi lai was present to monitor the welding process. The welding parameters as measured using QC's calibrated instruments appeared to be in general compliance with WPS-B-P-2312-TC-P4.

Unless otherwise noted, all work observed on this date appeared to generally comply with applicable contract documents.

Summary of Conversations:

As mention above

Comments

This report is for the purpose of determining conformance with the contract documents and is not for the purpose of making repair or fit for purpose recommendations. Should you require recommendations concerning repairs or remedial efforts please contact Eric Tsang 150-00422372, who represents the Office of Structural Materials for your project.

Inspected By:	Sukanthan, Dhanasingh	Quality Assurance Inspector
Reviewed By:	Hall,Steven	QA Reviewer